



**protect**

**Protect Membranes**  
2 Brooklands Road, Sale, Cheshire M33 3SS

Telephone **0161 905 5700**  
Fax **0161 905 2085**  
Email [info@protectmembranes.com](mailto:info@protectmembranes.com)  
Website [www.protectmembranes.com](http://www.protectmembranes.com)

### Calculation of interstitial condensation

by ICond Calculator version 2.03 - Printed on 10 Apr 2018 at 15:56

#### Element type: Roof – Structural Insulated Panel

Calculation Method: BS EN ISO 13788

#### 194mm Flat Roof with EPDM and 50mm Thermaline

##### Construction Details

<u>Layer</u>	<u>d</u> mm	<u><math>\lambda</math></u> W/m·K	<u>rv</u> MN·s/g·m	<u>R layer</u> m <sup>2</sup> K/W	<u>Rv layer</u> MN·s/g	<u>Description</u>
1	50	0.021	60.0	2.381	3.0	Rsi
2	22	R-value	Rv-value	0.530	0.050	Gyproc Thermaline Super
3			Rv-value		689	Air layer unventilated
4	11	0.130	50.0	0.085	0.55	Protect VC Foil Ultra Insulating AVCL m
5	172	0.030	7.00	5.733	1.2	SIP - OSB
6	11	0.130	50.0	0.085	0.55	Lambdatherm
7			Rv-value		0.080	SIP - OSB
8	50	R-value	Rv-value		##	Protect VP400 Plus LR
9	19	0.130	450		##	Air layer ventilated
10	1	0.200	250000		##	Plywood sheathing
				0.100 #		EPDM Rubber
					694	Rse
<u>336 mm (total roof thickness)</u>			<u>9.014</u>			

**Boundary conditions** Manchester (Manchester.hgt)

Return period 2 years (mean external temperature and RH)

Internal Humidity: BS 5250 Class 3

##### Results

No condensation

<u>Month</u>	<u>Internal T °C</u>	<u>Internal RH %</u>	<u>External T °C</u>	<u>External RH %</u>	<u>RH % at internal surface</u>
October	20.0	62	10.6	83	62
November	20.0	59	6.4	85	60
December	20.0	58	4.6	86	59
January	20.0	57	3.9	85	58
February	20.0	56	3.9	82	57
March	20.0	56	5.7	79	57
April	20.0	55	8.0	75	55
May	20.0	57	11.3	73	57
June	20.0	62	14.2	75	62
July	20.0	65	15.8	75	65
August	20.0	66	15.7	77	66
September	20.0	64	13.5	80	64

The U value result has been determined as follows:

**Bridging:** A thermal bridge percentage for the timber studs of 12.5% has been used in accordance with BR 443: 2006 Conventions for U values (section 4.5.1 (ii)).

**Correction level:** A correction level of 0 has been used in accordance with Table F1 of BS EN ISO 6946: 2017 Building components and Building elements - Thermal transmittance - Calculation methods. Please check to confirm and advise if any amendments are required.

Calculated By **Connor Smith** – Technical Officer

